

RFQ TITLE:	REPAIRING CAPASITOR BANK AT DPW SABAH SDN. BHD
RFQ NO.:	RFQ-DP-25-0294
RFQ CLOSING DATE & TIME:	06 ^{тн} AUGUST 2025 @ 1430 HRS

No.	Description	Qty.	Unit Price (RM)	Total Price (RM)
1.	PRELIMINARIES			
1.0	Allow for mobilization and demobilization of tools, equipment and site cleaning throughout the duration of the work.	LS	-	
1.1	Allow for insurances on All risks and workmen compensation.	LS	-	
1.2	To comply to Health, Safety and Environment requirement not less than PPE.	LS	-	
2.	SCOPE OF WORKS			
2.0	To supply and replace faulty Capacitor Bank at sub station no.1 complete with sufficient size of cable and cable lug from contactor to capacitor bank. i. Feeder no.1 step no.4 & 10 ii. Feeder no.2 step no.1,2,3,4,5,8 & 10 ii. Feeder no.3 step no.8 iv. Feeder no.4 step 1 to 10	20 nos		
2.1	To replace new faulty contactor, include 10mm cable and cable lug from MCCB to contactor. **Notes: -INSTALLATION WARANTY NEEDED -Site visit must be monitoring with DPW electrician -Apply PPE for DPW HSE electrical safety requirement	5 nos		
	 Notes: i. Ensure you are being equipped with suitable PPE i.e. Electrical insulating gloves, high visibility vest, safety helmet and shoes. ii. Ensure Port pass is applied prior to entering. Port pass can be applied through the link below: - https://saportal.spsb.com.my/portpassds/web/index.php (Please refer Appendix A for specification) Contact Person: Mr. Harith (011-14116825) 			
		То	tal (RM):	

- Upon being awarded the works, we agree to attend the mandatory safety briefing with full PPE gear not less than **safety boot**, **safety helmet and reflective safety vest**, failing which will not be allowed to attend and delay in work completion will not be compensated.
- All Contractor must attend site Visit, Attend recorded. Failed to attend DPWS entitled Rejection any offer.
- All Contractor must already attend Safety training by DPWS.

	Agreed	Not Agree
		
Company stamp & Initial:	Date:	



SPECIFICATIONS

PROJECT: REPAIRING CAPASITOR BANK AT DPW SABAH SDN. BHD

RFQ REF.: RFQ-DP-25-0294

Spec of Contactor























No	Attributes	Value
1	Product	Contactor
2	Brand	ABB
3	Model	UA50-30
4	Volt and Frequency	220-230V & 50HZ

Specs Of Capacitor



No	Attributes	Value
1	Product	Power Capacitor
1	Brand	EPCOS
3	Model	MKD440-D-30.0
4	Frequency	50 HZ
5	Rated KVAr	30 KVAr
6	Rated Volt Cap	440V
7	Rated Current	39.4A

Appendix B



SITE VISIT FORM

PROJECT

Date

RFQ REF . CLOSING DATE	: RFQ-DP-25-0294 : 06 th AUGUST 2025 @ 1430 HRS
This form must be s	igned by DPWS representative during the site visit.
	completed and submitted together with the quotation Document at the same time ed envelop before the stipulated closing date of bidding.

: REPAIRING CAPASITOR BANK AT DPW SABAH SDN. BHD

I/we,		for and on behalf
of Company		
existing site conditions, on site for cost estimat	scope o	and confirm that we have satisfied ourself with the of work requirements and have obtained relevant thorough information uring proper completion of the works. All cost submitted with this t and no future variation order.
Signature of Contractor	:	
Name of Contractor	:	
Address	:	
Date	:	
DPWS representative		
Name:		